



Ref. Certif. No.

SG PSB-LE-00047M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE)METHODE OC**CB TEST CERTIFICATE**
CERTIFICAT D'ESSAI OCProduct
Produit

Flood lights

Name and address of the applicant
Nom et adresse du demandeurNJZ Lighting Technology Co., Ltd.
No.58 Hengguang Road, Nanjing Economic, and Technological Development Zone
210038 Nanjing, Jiangsu, PEOPLE'S REPUBLIC OF CHINAName and address of the manufacturer
Nom et adresse du fabricantNJZ Lighting Technology Co., Ltd.
No.58 Hengguang Road, Nanjing Economic, and Technological Development Zone,
210038 Nanjing, Jiangsu, PEOPLE'S REPUBLIC OF CHINAName and address of the factory
Nom et adresse de l'usineNJZ Lighting Technology Co., Ltd.
No.58 Hengguang Road, Nanjing Economic, and Technological Development Zone,
210038 Nanjing, Jiangsu, PEOPLE'S REPUBLIC OF CHINARatings and principal characteristics
Valeurs nominales et caractéristiques principalesRated voltage: 200-240 V~
Rated frequency: 50/60 Hz
Rated wattage: NJZ-FLB-50: 50 W, NJZ-FLB-100: 100 W,
NJZ-FLB-150: 150 W, NJZ-FLB-200: 200 W,
NJZ-FLB-300: 300 W, NJZ-FLB-400: 400 W
Protection Class: Class I
Degree of protection: IP65 & IP67
ta: 50°CModel/type Ref.
Ref. de typeNJZ-FLB-50, NJZ-FLB-100, NJZ-FLB-150,
NJZ-FLB-200, NJZ-FLB-300, NJZ-FLB-400Additional information (if necessary)
Information complémentaire (si nécessaire)Certificate SG PSB-LE-00047A1 issued on 2016-08-18 is replaced due to
technical changes. Comply with IEC 62493:2015.A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60598-1:2014
IEC 60598-2-5:1998
IEC 62471:2006as shown in the Test Report Ref. No.
which forms part of this certificate
comme indiqué dans le Rapport d'essais numéro
de référence qui constitue une partie de ce
certificatTÜV SÜD PSB Pte Ltd
083-1656701-100This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Date, 2016-12-14
CBS 16 12 95986 008
(Na Zhang)

PSB Singapore

TÜV SÜD PSB Pte Ltd · 1 Science Park Drive · Singapore 118221