



Product Service

# Attestation of Conformity

No. N8A 16 07 95986 004

**Holder of Certificate:** NJZ Lighting Technology Co., Ltd.No.58 Hengguang Road, Nanjing Economic  
and Technological Development Zone  
210038 Nanjing, Jiangsu  
PEOPLE'S REPUBLIC OF CHINA**Product:** Flood lights**Model(s):** NJZ-FLB-50, NJZ-FLB-100, NJZ-FLB-150,  
NJZ-FLB-200, NJZ-FLB-300, NJZ-FLB-400

**Parameters:**

Rated voltage:	200-240 V~
Rated frequency:	50/60 Hz
Rated wattage:	
NJZ-FLB-50:	50 W
NJZ-FLB-100:	100 W
NJZ-FLB-150:	150 W
NJZ-FLB-200:	200 W
NJZ-FLB-300:	300 W
NJZ-FLB-400:	400 W
Protection Class:	Class I
Degree of protection:	IP65 & IP67
ta:	50°C

**Tested according to:**

EN 60598-1:	2015
EN 60598-2-5:	1998
EN 62471:	2008
EN 62493:	2015

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 704021656701-00**Date,** 2016-07-07

(Na Zhang)



**CE** After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1