


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

DATA OF LAMP		PHOTOMETRIC DATA Eff: 134.79 lm/W			
NJZ-FEL-MODEL-V01-RZ-60-1-T (120V)		Imax(cd)	3819	S/MH(C0/180)	1.01
NOMINAL POWER(W)	40	LOR(%)	100.0	S/MH(C90/270)	1.03
RATED VOLTAGE(V)	120	TOTAL FLUX(lm)	5356.1	η UP,DN(C0-180)	0.0,50.3
NOMINAL FLUX(lm)	5356.11	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.7
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.00
TEST VOLTAGE(V)	120	η down(%)	100.0	CIBSE SHR MAX	1.05

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	3687	3661	3659	3629	3666	3658	3698	3686	0- 10	355.4	355.4	6.64,6.64
20	3260	3263	3327	3192	3286	3213	3352	3284	10- 20	985.4	1341	25,25
30	2329	2420	2471	2398	2393	2408	2466	2412	20- 30	1310	2650	49.5,49.5
40	1323	1409	1436	1454	1405	1425	1371	1390	30- 40	1182	3832	71.5,71.5
50	657.2	694.1	706.4	740.6	701.8	697.0	652.0	692.1	40- 50	785.1	4617	86.2,86.2
60	303.2	325.0	328.1	358.6	326.6	314.4	291.5	331.1	50- 60	441.7	5059	94.5,94.5
70	125.5	140.0	131.8	152.5	137.9	123.8	80.30	133.5	60- 70	215.5	5274	98.5,98.5
80	28.63	31.39	4.089	32.54	34.65	20.57	2.136	21.91	70- 80	75.76	5350	99.9,99.9
90	0.5088	0	0	0	0.4278	0	0	0	80- 90	5.877	5356	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 4274.6 lm

%lum = 79.8%

%lamp = 79.8%

Conical surface Flux(120deg): 5059 lm

%lum = 94.5%


%lamp = 94.5%

H(β) Range:-90 - 90DEG
 H(β) Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:31 May 2019

V(B) Range:-80 - 80DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	496	0
80	1649	235
75	2707	2627
70	3669	3854
65	4690	5449
60	6063	6562
55	7889	9025
50	10224	10990
45	13288	15152


H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.09	1.06	1.03	1.06	1.04	1.01	1.02	1.00	.98	.98	.97	.95	.95	.94	.92	.90
2.0	.99	.94	.89	.97	.92	.88	.93	.90	.86	.90	.87	.84	.88	.85	.83	.81
3.0	.90	.84	.79	.88	.83	.78	.86	.81	.77	.83	.79	.75	.81	.77	.74	.72
4.0	.82	.75	.70	.81	.74	.69	.78	.73	.69	.76	.72	.68	.74	.70	.67	.65
5.0	.75	.68	.63	.74	.67	.62	.72	.66	.62	.70	.65	.61	.69	.64	.61	.59
6.0	.69	.62	.57	.68	.62	.57	.67	.61	.56	.65	.60	.56	.64	.59	.55	.54
7.0	.64	.57	.52	.63	.56	.52	.62	.56	.51	.61	.55	.51	.59	.54	.51	.49
8.0	.59	.52	.47	.59	.52	.47	.58	.51	.47	.57	.51	.47	.55	.50	.47	.45
9.0	.55	.48	.44	.55	.48	.44	.54	.48	.43	.53	.47	.43	.52	.47	.43	.42
10.0	.52	.45	.40	.51	.45	.40	.50	.44	.40	.50	.44	.40	.49	.44	.40	.38



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.220	.125	.040	.213	.122	.039	.200	.115	.037	.188	.109	.035	.178	.103	.033		
2.0	.214	.117	.036	.208	.114	.035	.197	.109	.034	.187	.105	.033	.177	.100	.032		
3.0	.204	.108	.032	.198	.106	.032	.189	.102	.031	.180	.099	.030	.172	.095	.029		
4.0	.193	.100	.029	.188	.099	.029	.180	.095	.028	.172	.092	.028	.165	.090	.027		
5.0	.182	.093	.027	.178	.092	.027	.171	.089	.026	.164	.087	.026	.158	.084	.025		
6.0	.172	.086	.025	.169	.085	.025	.162	.083	.024	.156	.081	.024	.151	.079	.024		
7.0	.163	.081	.023	.160	.080	.023	.154	.078	.022	.149	.076	.022	.144	.075	.022		
8.0	.155	.076	.021	.152	.075	.021	.147	.073	.021	.142	.072	.021	.137	.070	.021		
9.0	.147	.071	.020	.145	.070	.020	.140	.069	.020	.135	.068	.019	.131	.067	.019		
10.0	.140	.067	.019	.138	.066	.019	.133	.065	.018	.129	.064	.018	.126	.063	.018		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.174	.157	.141	.149	.135	.122	.102	.093	.084	.059	.054	.049	.019	.017	.016	
2.0	.162	.132	.107	.139	.114	.093	.095	.079	.065	.055	.046	.038	.018	.015	.012	
3.0	.152	.114	.084	.130	.098	.073	.089	.068	.051	.052	.040	.030	.017	.013	.010	
4.0	.143	.100	.067	.123	.086	.058	.084	.060	.041	.049	.035	.024	.016	.011	.008	
5.0	.135	.089	.054	.116	.077	.047	.080	.054	.033	.046	.031	.020	.015	.010	.007	
6.0	.128	.080	.045	.110	.069	.039	.076	.048	.028	.044	.028	.017	.014	.009	.005	
7.0	.122	.073	.038	.105	.063	.033	.072	.044	.024	.042	.026	.014	.014	.009	.005	
8.0	.116	.067	.033	.100	.058	.028	.069	.041	.020	.040	.024	.012	.013	.008	.004	
9.0	.111	.062	.028	.096	.054	.025	.066	.038	.018	.039	.022	.010	.012	.007	.003	
10.0	.106	.057	.025	.091	.050	.022	.063	.035	.015	.037	.021	.009	.012	.007	.003	

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm										
NAME: LED Explosion-proof Flood Light					TYPE:Floodlight			WEIGHT:N/A		
SPEC.:40W/OSLON Square/5000K					DIM.: N/A			SERIAL No.:N/A		
MFR.: NJZ Lighting Technology Co.,Ltd					SUR.:N/A			Shielding Angle:N/A		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	13.1	14.3	13.3	14.4	14.6	13.5	14.7	13.7	14.8	15.0
3H	13.4	14.4	13.6	14.7	14.9	13.8	14.9	14.1	15.1	15.3
4H	13.4	14.5	13.7	14.7	14.9	13.8	14.8	14.1	15.1	15.3
6H	13.4	14.4	13.7	14.6	14.9	13.7	14.7	14.1	15.0	15.2
8H	13.4	14.3	13.7	14.6	14.9	13.7	14.6	14.0	14.9	15.2
12H	13.3	14.2	13.7	14.5	14.8	13.7	14.5	14.0	14.8	15.1
4H 2H	13.2	14.2	13.5	14.5	14.7	13.5	14.6	13.8	14.8	15.1
3H	13.6	14.5	13.9	14.8	15.1	14.0	14.9	14.3	15.2	15.4
4H	13.7	14.5	14.1	14.9	15.2	14.1	14.9	14.4	15.2	15.5
6H	13.8	14.5	14.2	14.8	15.2	14.0	14.7	14.4	15.1	15.4
8H	13.8	14.4	14.2	14.8	15.2	14.0	14.6	14.4	15.0	15.4
12H	13.7	14.3	14.1	14.7	15.1	13.9	14.5	14.3	14.9	15.3
8H 4H	13.7	14.4	14.1	14.7	15.1	14.0	14.7	14.4	15.1	15.4
6H	13.8	14.4	14.3	14.8	15.2	14.0	14.5	14.4	14.9	15.4
8H	13.8	14.3	14.3	14.7	15.2	14.0	14.4	14.4	14.9	15.3
12H	13.8	14.2	14.3	14.6	15.1	13.9	14.3	14.4	14.8	15.2
12H 4H	13.7	14.3	14.1	14.7	15.1	14.0	14.6	14.4	15.0	15.4
6H	13.8	14.3	14.2	14.7	15.1	14.0	14.4	14.4	14.9	15.3
8H	13.8	14.2	14.3	14.6	15.1	13.9	14.3	14.4	14.8	15.2
Variations with the observer position at spacings:										
S = 1.0H	+ 1.0 / - 1.5					+ 1.0 / - 1.4				
1.5H	+ 1.1 / - 1.0					+ 1.1 / - 1.1				
2.0H	+ 2.1 / - 1.7					+ 2.3 / - 2.1				

CIE Pub.117, 5356 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 5.8$)

$H(\beta)$ Range:-90 - 90DEG
 $H(\beta)$ Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:31 May 2019

$V(B)$ Range:-80 - 80DEG
 $V(B)$ Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

UTILIZATION FACTORS TABLE

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	74	65	59	73	65	59	72	64	59	54
0.80	83	74	69	82	74	69	80	73	68	63
1.00	90	82	77	89	81	76	87	82	76	71
1.25	95	88	83	94	87	83	92	86	82	76
1.50	99	92	88	98	92	87	95	90	86	80
2.00	104	98	94	102	97	93	99	95	91	85
2.50	106	101	97	104	100	96	101	97	94	87
3.00	108	104	100	106	102	99	103	100	97	90
4.00	111	107	104	109	106	103	105	102	100	92
5.00	113	109	107	110	108	105	106	104	102	94
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

$H(\beta)$ Range:-90 - 90DEG
 $H(\beta)$ Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:31 May 2019

$V(B)$ Range:-80 - 80DEG
 $V(B)$ Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A




H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

AAI Figure

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Flux out:3284 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A


AvgL	cd/m2
L_0~180 (65) av	4888
L_0~180 (75) av	2879
L_0~180 (85) av	665
L_90~270 (65) av	4920
L_90~270 (75) av	2109
L_90~270 (85) av	0
L_45 (65) av	5265
L_45 (75) av	2780
L_45 (85) av	106

Standard: GB/T 29293-2012

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

Planar Illuminance Curve



H(β) Range:-90 - 90DEG
 H(β) Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:31 May 2019

V(B) Range:-80 - 80DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--1

UNIT: cd

[illegible]

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--2

UNIT: cd

[illegible]

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

```
V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:
```

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--3

UNIT: cd

[illegible]

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

```
V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:
```

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:119.84V I:0.3354A P:39.738W PF:0.9888 Freq:59.98Hz Lamp Flux:5356.11x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:40W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--4

UNIT: cd

[illegible]

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:31 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks: