

**Floodlight Summary:**

Report based on lamp delivering 1000 lumens.

Maximum Intensity	6424.8 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	38.7V x 37.7H
	At 50% of Imax	17.1V x 17.6H
	At 90% of Imax	5.3V x 6.4H

Beam Flux	Total	996.6 lumens per klm.
	To 10% of Imax	710.3 lumens per klm.
	To 50% of Imax	287.2 lumens per klm.
	To 90% of Imax	23.3 lumens per klm.

Upward LOR	0.0 %
Downward LOR	99.7 %

Luminaire Efficiency (Light Output Ratio)	100.0 %
---	---------

---


H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

---

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

# LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:220.18V I:0.8815A P:184.51W PF:0.9506 Freq:49.99Hz Lamp Flux:26297.1x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:200W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



DATA OF LAMP		Eff:142.52lm/W	
NJZMODEL200-V01-RZ-15-PC-BL		Imax(cd)	168954
NOMINAL POWER(W)	200	AVAILABILITY(%)	72.9
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	19171
NOMINAL FLUX(lm)	26297.1	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	26297
TEST VOLTAGE(V)	220	θ @50%(H,V)	18,17DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
80	0.04	0.27	0.78	1.58	2.57	3.54	4.38	4.94	5.25	5.26	4.98	4.48	3.67	2.68	1.66	0.82	0.29	0.04	47.2	0.00
70	0.06	0.48	1.45	2.93	4.68	6.35	7.66	8.49	8.85	8.87	8.59	7.89	6.67	4.92	3.05	1.50	0.50	0.06	83.0	0.00
60	0.09	0.73	2.17	4.26	6.73	9.05	10.8	12.0	12.6	12.6	12.3	11.6	10.1	7.22	4.44	2.24	0.75	0.09	120	0.00
50	0.11	0.97	2.81	5.37	8.49	12.1	16.0	19.8	21.8	21.9	21.0	19.3	15.1	9.42	5.58	2.89	0.98	0.12	184	0.00
40	0.14	1.17	3.32	6.17	10.1	17.8	31.3	47.1	58.3	59.4	51.9	39.9	23.3	11.4	6.39	3.39	1.18	0.14	372	0.00
30	0.16	1.33	3.68	6.70	11.6	27.6	66.6	131	196	202	146	81.8	34.1	13.0	6.91	3.73	1.33	0.16	934	0.00
20	0.18	1.44	3.90	7.04	13.3	39.8	127	345	755	823	391	146	45.4	14.5	7.24	3.93	1.43	0.17	2726	1433
10	0.19	1.50	4.00	7.23	14.8	50.5	197	733	2409	2587	812	207	53.4	15.6	7.41	4.02	1.48	0.18	7105	6345
0	0.19	1.51	4.01	7.29	15.3	54.3	225	1008	3576	3321	863	206	52.3	15.3	7.37	4.01	1.48	0.18	9361	8626
-10	0.18	1.46	3.94	7.16	14.5	47.5	170	536	1240	993	395	142	42.6	14.0	7.18	3.92	1.43	0.17	3620	2768
-20	0.17	1.37	3.76	6.87	12.9	36.0	95.4	175	176	157	130	74.0	29.6	12.1	6.83	3.72	1.32	0.15	922	0.00
-30	0.14	1.23	3.45	6.39	11.2	24.9	45.9	56.6	54.1	51.1	46.2	33.6	18.7	10.4	6.32	3.38	1.17	0.13	375	0.00
-40	0.12	1.04	2.99	5.68	9.58	16.1	21.1	20.7	19.3	18.9	18.4	15.5	12.1	8.75	5.54	2.88	0.97	0.10	180	0.00
-50	0.09	0.81	2.38	4.65	7.57	10.4	11.2	11.3	11.5	11.5	11.2	10.6	9.30	7.06	4.48	2.26	0.74	0.07	117	0.00
-60	0.06	0.56	1.67	3.33	5.33	7.08	8.24	8.95	9.26	9.23	8.88	8.12	6.80	5.04	3.14	1.54	0.49	0.04	87.8	0.00
-70	0.04	0.32	0.93	1.88	3.02	4.09	4.96	5.53	5.78	5.77	5.47	4.83	3.90	2.82	1.71	0.82	0.26	0.03	52.1	0.00
-80	0.02	0.10	0.24	0.45	0.69	0.90	1.11	1.26	1.33	1.32	1.18	0.98	0.75	0.51	0.28	0.13	0.04	0.01	11.3	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90 -80 -70 -60 -50 -40 -30 -20 HORIZONTAL (DEG) 20 30 40 50 60 70 80 90																				
Φ t	1.97	16.3	45.5	85.0	152	368	1044	3124	8560	8289	2927	1013	368	155	85.5	45.2	15.8	1.82	26297	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	50.9	2035	7696	7504	1870	15.2	0.00	0.00	0.00	0.00	0.00	0.00	---	19171

one-half-peak spread: U:9.8,D:7.5 , L:8.6,R:9.1


NEMA Beam Type: Type 3

H(β) Range:-90 - 90DEG  
H(β) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

# ISOCANDELA DIAGRAM

Test:U:220.18V I:0.8815A P:184.51W PF:0.9506 Freq:49.99Hz Lamp Flux:26297.1x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:200W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A




H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### ISOLUX DIAGRAM


Test:U:220.18V I:0.8815A P:184.51W PF:0.9506 Freq:49.99Hz Lamp Flux:26297.1x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:200W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### Planar Illuminance Curve




H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### AAI Figure

Test:U:220.18V I:0.8815A P:184.51W PF:0.9506 Freq:49.99Hz Lamp Flux:26297.1x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:200W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.18V I:0.8815A P:184.51W PF:0.9506 Freq:49.99Hz Lamp Flux:26297.1x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:200W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--1

UNIT: ×100cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.07	0.08	0.18	0.27	0.36	0.46	0.56	0.67	0.78	0.87	0.95	1.02	1.08	1.12	1.16	1.19	1.21	1.21	1.21
-75	0.05	0.07	0.16	0.34	0.48	0.65	0.82	0.99	1.17	1.34	1.48	1.60	1.69	1.77	1.82	1.85	1.87	1.88	1.88
-70	0.07	0.13	0.35	0.57	0.80	1.04	1.29	1.53	1.77	1.98	2.16	2.30	2.41	2.47	2.52	2.54	2.55	2.55	2.55
-65	0.05	0.08	0.27	0.58	0.86	1.16	1.47	1.77	2.08	2.36	2.62	2.82	2.97	3.05	3.09	3.10	3.11	3.11	3.11
-60	0.06	0.21	0.58	0.92	1.28	1.65	2.02	2.38	2.74	3.07	3.34	3.54	3.64	3.67	3.68	3.67	3.68	3.68	3.68
-55	0.04	0.10	0.42	0.85	1.25	1.67	2.10	2.50	2.90	3.32	3.75	4.14	4.44	4.54	4.51	4.48	4.47	4.47	4.48
-50	0.06	0.30	0.80	1.25	1.72	2.21	2.66	3.09	3.56	4.09	4.64	5.15	5.40	5.37	5.30	5.26	5.26	5.28	5.28
-45	0.02	0.13	0.58	1.10	1.60	2.12	2.63	3.08	3.53	4.09	4.88	5.95	7.17	8.05	8.44	8.61	8.73	8.84	8.87
-40	0.07	0.42	1.00	1.55	2.10	2.66	3.15	3.59	4.13	4.97	6.32	8.24	10.1	11.3	11.8	12.1	12.3	12.4	12.4
-35	0.00	0.16	0.73	1.31	1.89	2.47	3.02	3.49	3.95	4.63	5.97	8.40	11.9	15.8	19.0	21.9	24.3	26.0	26.8
-30	0.07	0.55	1.15	1.77	2.38	2.96	3.47	3.91	4.50	5.67	8.24	12.6	18.4	24.3	29.8	34.8	38.6	40.8	41.0
-25	0.00	0.21	0.83	1.47	2.11	2.72	3.27	3.74	4.24	5.10	7.12	11.3	18.4	28.5	41.8	57.4	74.7	90.0	98.1
-20	0.08	0.63	1.27	1.94	2.58	3.16	3.66	4.12	4.84	6.52	10.4	17.8	29.7	48.0	72.0	101	130	151	154
-15	0.00	0.28	0.90	1.58	2.25	2.87	3.40	3.89	4.43	5.54	8.27	14.2	25.3	45.0	78.4	132	221	363	482
-10	0.09	0.66	1.34	2.03	2.68	3.24	3.74	4.25	5.13	7.24	12.3	22.3	42.0	77.8	143	258	472	748	796
-5	0.00	0.32	0.93	1.64	2.31	2.93	3.45	3.94	4.55	5.82	8.98	16.0	30.0	57.5	111	213	442	886	1236
0	0.12	0.67	1.36	2.06	2.71	3.26	3.75	4.29	5.23	7.49	12.9	24.1	47.0	92.1	184	394	924	1518	1636
5	0.00	0.32	0.93	1.63	2.30	2.92	3.44	3.93	4.52	5.74	8.79	15.6	29.1	55.4	106	202	412	815	1125
10	0.14	0.65	1.32	2.01	2.66	3.21	3.72	4.21	5.03	7.00	11.6	20.9	38.9	71.0	127	218	369	548	579
15	0.00	0.30	0.88	1.56	2.21	2.83	3.37	3.85	4.37	5.37	7.79	13.1	22.8	40.1	68.4	113	181	279	356
20	0.14	0.61	1.24	1.90	2.53	3.11	3.61	4.06	4.70	6.13	9.43	15.5	25.4	40.0	59.6	82.3	105	121	123
25	0.00	0.28	0.81	1.43	2.05	2.66	3.20	3.67	4.13	4.88	6.51	9.85	15.3	23.2	33.8	46.6	60.4	72.5	78.6
30	0.12	0.54	1.11	1.71	2.30	2.88	3.38	3.81	4.33	5.27	7.14	10.1	14.0	18.5	23.1	27.4	30.9	33.1	33.4
35	0.00	0.25	0.70	1.26	1.82	2.38	2.92	3.37	3.80	4.38	5.34	6.90	9.05	11.7	14.4	17.2	19.6	21.3	22.1
40	0.11	0.46	0.95	1.48	2.01	2.54	3.02	3.44	3.91	4.53	5.27	6.14	7.13	8.11	9.09	9.96	10.5	10.6	10.6
45	0.00	0.21	0.58	1.04	1.52	2.01	2.50	2.92	3.33	3.79	4.32	4.85	5.42	6.00	6.57	7.13	7.54	7.74	7.80
50	0.10	0.37	0.75	1.18	1.62	2.08	2.50	2.90	3.30	3.68	3.99	4.23	4.42	4.57	4.73	4.85	4.89	4.92	4.94
55	0.00	0.16	0.44	0.79	1.16	1.56	1.95	2.32	2.68	3.03	3.34	3.58	3.76	3.90	4.01	4.11	4.17	4.19	4.21
60	0.09	0.28	0.54	0.85	1.17	1.52	1.85	2.18	2.49	2.77	2.99	3.16	3.28	3.36	3.42	3.45	3.46	3.47	3.48
65	0.01	0.12	0.31	0.53	0.78	1.05	1.33	1.60	1.87	2.12	2.33	2.51	2.64	2.74	2.81	2.86	2.88	2.89	2.90
70	0.07	0.16	0.33	0.51	0.70	0.92	1.14	1.35	1.56	1.74	1.89	2.02	2.13	2.21	2.27	2.30	2.32	2.32	2.33
75	0.03	0.09	0.18	0.30	0.42	0.55	0.70	0.85	1.00	1.14	1.26	1.36	1.44	1.52	1.58	1.61	1.63	1.65	1.66
80	0.06	0.09	0.16	0.23	0.29	0.36	0.44	0.53	0.61	0.68	0.75	0.80	0.85	0.90	0.93	0.95	0.97	0.99	1.00
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

H(β) Range:-90 - 90DEG  
H(β) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.18V I:0.8815A P:184.51W PF:0.9506 Freq:49.99Hz Lamp Flux:26297.1x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:200W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--2

UNIT: ×100cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-80	1.21	1.18	1.15	1.11	1.06	1.00	0.93	0.86	0.77	0.67	0.56	0.46	0.36	0.27	0.20	0.10	0.06	0.06	
-75	1.88	1.87	1.85	1.81	1.76	1.69	1.59	1.49	1.36	1.21	1.04	0.87	0.70	0.53	0.39	0.24	0.10	0.06	
-70	2.54	2.53	2.50	2.45	2.37	2.27	2.13	1.97	1.78	1.56	1.32	1.08	0.83	0.61	0.41	0.18	0.07	0.05	
-65	3.11	3.10	3.08	3.05	3.00	2.91	2.78	2.62	2.41	2.16	1.88	1.58	1.28	0.98	0.70	0.42	0.15	0.06	
-60	3.67	3.65	3.64	3.60	3.53	3.41	3.25	3.03	2.76	2.43	2.09	1.73	1.36	1.00	0.66	0.29	0.08	0.03	
-55	4.47	4.46	4.43	4.36	4.25	4.12	3.93	3.69	3.39	3.03	2.65	2.27	1.86	1.44	1.03	0.64	0.22	0.06	
-50	5.26	5.23	5.16	5.00	4.83	4.61	4.33	4.01	3.61	3.18	2.76	2.33	1.86	1.38	0.92	0.45	0.10	0.02	
-45	8.84	8.72	8.43	7.85	7.05	6.24	5.48	4.84	4.27	3.73	3.27	2.85	2.37	1.85	1.34	0.84	0.31	0.06	
-40	12.3	11.9	11.1	9.77	8.28	6.94	5.83	4.99	4.26	3.71	3.28	2.80	2.26	1.70	1.15	0.61	0.12	0.00	
-35	26.5	24.9	22.3	18.9	15.2	11.7	8.63	6.45	5.11	4.26	3.72	3.27	2.76	2.19	1.60	1.01	0.43	0.06	
-30	39.1	35.0	29.5	23.6	17.9	12.6	8.58	6.16	4.84	4.11	3.63	3.14	2.58	1.97	1.35	0.73	0.15	0.00	
-25	94.4	80.5	63.2	46.6	32.6	21.6	13.6	8.56	5.98	4.69	4.02	3.55	3.03	2.44	1.80	1.15	0.53	0.06	
-20	135	105	76.1	52.1	33.3	20.3	11.9	7.41	5.37	4.37	3.84	3.35	2.79	2.15	1.48	0.81	0.20	0.00	
-15	434	279	164	98.8	58.2	33.9	19.0	10.7	6.83	5.06	4.22	3.70	3.19	2.60	1.94	1.25	0.59	0.07	
-10	550	299	165	92.0	51.2	27.8	15.0	8.61	5.85	4.59	3.96	3.45	2.91	2.27	1.58	0.87	0.28	0.00	
-5	1094	641	296	151	79.4	42.9	22.7	12.2	7.41	5.32	4.32	3.76	3.25	2.68	2.01	1.30	0.61	0.09	
0	1117	501	225	113	58.8	30.9	16.2	9.13	6.06	4.68	3.98	3.47	2.94	2.30	1.60	0.89	0.28	0.00	
5	999	599	282	147	78.6	42.7	22.8	12.4	7.47	5.33	4.33	3.77	3.26	2.68	2.01	1.30	0.61	0.11	
10	425	257	152	88.7	50.4	27.8	15.3	8.78	5.92	4.60	3.97	3.46	2.91	2.27	1.58	0.87	0.28	0.00	
15	325	227	144	92.1	56.6	33.8	19.4	11.1	6.98	5.10	4.23	3.72	3.19	2.60	1.94	1.25	0.59	0.12	
20	110	89.7	68.6	49.3	33.0	20.8	12.5	7.71	5.46	4.40	3.85	3.36	2.79	2.15	1.48	0.82	0.26	0.00	
25	75.9	66.7	54.8	42.9	31.9	22.3	14.5	9.17	6.22	4.76	4.04	3.56	3.04	2.44	1.80	1.15	0.54	0.11	
30	32.0	29.6	26.5	23.0	18.8	13.9	9.55	6.61	4.98	4.15	3.64	3.16	2.58	1.96	1.34	0.73	0.24	0.00	
35	21.8	20.8	19.3	17.6	15.6	13.0	9.89	7.20	5.41	4.35	3.74	3.28	2.76	2.18	1.59	1.01	0.47	0.10	
40	10.5	10.3	10.1	9.90	9.41	8.32	6.81	5.45	4.43	3.76	3.28	2.80	2.25	1.69	1.14	0.61	0.20	0.00	
45	7.77	7.69	7.60	7.51	7.42	7.09	6.33	5.36	4.49	3.79	3.28	2.83	2.35	1.83	1.32	0.83	0.39	0.09	
50	4.92	4.93	4.96	5.03	5.12	5.04	4.69	4.19	3.66	3.18	2.73	2.30	1.83	1.35	0.90	0.49	0.16	0.00	
55	4.21	4.20	4.21	4.24	4.27	4.28	4.14	3.83	3.44	3.02	2.62	2.22	1.82	1.40	1.00	0.62	0.30	0.09	
60	3.48	3.49	3.49	3.49	3.46	3.40	3.25	3.02	2.71	2.37	2.03	1.67	1.31	0.96	0.64	0.35	0.12	0.00	
65	2.90	2.91	2.90	2.90	2.87	2.82	2.72	2.56	2.34	2.09	1.81	1.52	1.22	0.93	0.66	0.41	0.20	0.08	
70	2.33	2.32	2.31	2.28	2.22	2.13	2.02	1.86	1.67	1.47	1.24	1.01	0.78	0.57	0.38	0.22	0.09	0.00	
75	1.66	1.65	1.64	1.62	1.58	1.52	1.45	1.35	1.23	1.10	0.95	0.79	0.63	0.48	0.35	0.23	0.11	0.07	
80	0.98	0.96	0.94	0.92	0.88	0.83	0.78	0.71	0.64	0.55	0.47	0.38	0.31	0.24	0.18	0.10	0.07	0.03	
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

H(β) Range:-90 - 90DEG  
H(β) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:25 October 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks: