

## Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	5439.4 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	44.1V x 39.5H
	At 50% of Imax	21.0V x 18.3H
	At 90% of Imax	6.1V x 7.0H

Beam Flux	Total	999.3 lumens per klm.
	To 10% of Imax	730.1 lumens per klm.
	To 50% of Imax	334.2 lumens per klm.
	To 90% of Imax	35.4 lumens per klm.

Upward LOR	0.0 %
Downward LOR	99.9 %

Luminaire Efficiency (Light Output Ratio)	100.0 %
---	---------


---

H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:05 November 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

# LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:120.04V I:4.9262A P:580.57W PF:0.9818 Freq:59.98Hz Lamp Flux:82661.8x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:600W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



DATA OF LAMP		Eff:142.38lm/W	
NJZMODEL 600-V01-RZ-15-PC-BL		Imax(cd)	449633
NOMINAL POWER(W)	600	AVAILABILITY(%)	74.4
RATED VOLTAGE(V)	120	Avai. FLUX(lm)	61490
NOMINAL FLUX(lm)	82661.8	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	82662
TEST VOLTAGE(V)	120	θ @50% (H,V)	18,21DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
80	0.17	1.35	3.96	7.91	12.7	17.3	21.4	24.2	25.4	25.4	24.4	21.8	17.9	13.0	7.89	3.82	1.24	0.15	230	0.00
70	0.25	2.00	5.87	11.6	18.5	25.3	30.6	33.8	35.2	35.3	34.3	32.0	27.0	19.5	12.0	5.88	1.89	0.22	331	0.00
60	0.33	2.74	7.93	15.3	24.3	34.2	44.0	50.6	52.9	52.9	51.8	49.1	39.4	26.4	16.1	8.12	2.67	0.30	479	0.00
50	0.41	3.37	9.61	18.0	29.0	47.3	77.3	106	119	119	110	93.0	59.5	32.5	19.2	10.0	3.38	0.38	857	0.00
40	0.48	3.90	10.9	19.9	32.9	69.7	155	268	349	352	286	187	89.8	38.0	21.3	11.4	3.95	0.45	1899	0.00
30	0.53	4.27	11.7	21.1	37.1	101	294	682	1136	1148	725	343	126	43.6	22.6	12.3	4.39	0.51	4714	1450
	0.56	4.51	12.1	21.8	41.4	131	489	1598	4202	4287	1674	551	162	48.7	23.4	12.8	4.66	0.54	13265	10900
	0.56	4.58	12.2	22.1	43.6	147	629	2716	9496	9435	2732	698	184	51.9	23.8	13.0	4.80	0.57	26214	24293
	0.55	4.51	12.1	21.9	42.5	138	576	2504	8557	8250	2407	638	174	50.8	23.6	13.0	4.77	0.57	23419	21384
	0.49	4.27	11.7	21.2	38.5	110	370	1016	1793	1702	1007	420	141	46.4	23.1	12.7	4.62	0.55	6721	3462
	0.42	3.92	11.0	20.1	34.1	80.1	198	352	401	399	357	218	99.7	40.4	22.0	12.0	4.32	0.49	2253	0.00
-30	0.32	3.43	9.96	18.6	30.0	54.2	95.9	121	125	126	120	102	64.7	34.6	20.5	11.0	3.89	0.41	942	0.00
-40	0.24	2.82	8.52	16.3	26.1	37.7	48.9	53.9	54.0	53.6	53.7	50.8	41.4	28.9	18.1	9.54	3.30	0.32	508	0.00
-50	0.17	2.10	6.68	13.2	21.1	28.5	32.9	35.0	36.2	36.3	35.2	33.5	29.9	23.0	14.8	7.64	2.56	0.25	359	0.00
-60	0.12	1.36	4.57	9.37	15.1	20.5	24.7	27.3	28.5	28.7	27.8	25.7	21.9	16.7	10.7	5.44	1.74	0.19	270	0.00
-70	0.08	0.71	2.45	5.17	8.52	11.9	14.8	16.8	17.9	18.1	17.5	15.7	13.1	9.79	6.26	3.19	1.03	0.15	163	0.00
-80	0.03	0.18	0.52	1.07	1.79	2.54	3.29	3.87	4.27	4.37	4.12	3.60	2.94	2.22	1.42	0.75	0.27	0.06	37.3	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL (DEG)	20	30	40	50	60	70	80	90			
Φ t	5.71	50.0	142	265	457	1056	3105	9608	26432	26072	9667	3483	1294	526	287	153	53.5	6.09	82662	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	67.2	6401	24387	24129	6466	40.2	0.00	0.00	0.00	0.00	0.00	0.00	---	61490

one-half-peak spread: U:7.1,D:14.1 , L:8.8,R:9.6


NEMA Beam Type: Type 3

H(β) Range:-90 - 90DEG  
H(β) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:05 November 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### ISOCANDELA DIAGRAM

Test:U:120.04V I:4.9262A P:580.57W PF:0.9818 Freq:59.98Hz Lamp Flux:82661.8x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:600W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A




H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:05 November 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### ISOLUX DIAGRAM


Test:U:120.04V I:4.9262A P:580.57W PF:0.9818 Freq:59.98Hz Lamp Flux:82661.8x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:600W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:05 November 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### Planar Illuminance Curve




$H(\beta)$  Range:-90 - 90DEG  
 $H(\beta)$  Interval: 1.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:CL  
 Test Date:05 November 2019

$V(B)$  Range:-80 - 80DEG  
 $V(B)$  Interval: 5.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
 Humidity:65.0%  
 Test Distance:6.010m [K=1.0000]  
 Remarks:

### AAI Figure

Test:U:120.04V I:4.9262A P:580.57W PF:0.9818 Freq:59.98Hz Lamp Flux:82661.8x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:600W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Flux out:26071 lm



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H( $\beta$ ) Range:-90 - 90DEG  
H( $\beta$ ) Interval: 1.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:CL  
Test Date:05 November 2019

V(B) Range:-80 - 80DEG  
V(B) Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366  
Humidity:65.0%  
Test Distance:6.010m [K=1.0000]  
Remarks:

### LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.04V I:4.9262A P:580.57W PF:0.9818 Freq:59.98Hz Lamp Flux:82661.8x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:600W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--1

UNIT: ×100cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.17	0.20	0.30	0.55	0.85	1.14	1.45	1.76	2.09	2.40	2.67	2.92	3.15	3.35	3.50	3.63	3.75	3.82	3.87
-75	0.15	0.22	0.40	0.79	1.32	1.81	2.34	2.86	3.39	3.87	4.31	4.69	5.01	5.28	5.49	5.63	5.75	5.82	5.88
-70	0.15	0.29	0.61	1.24	1.99	2.70	3.45	4.18	4.88	5.53	6.11	6.59	6.99	7.30	7.54	7.67	7.77	7.85	7.89
-65	0.13	0.29	0.69	1.50	2.47	3.37	4.29	5.19	6.06	6.87	7.59	8.18	8.65	8.99	9.22	9.36	9.45	9.52	9.57
-60	0.14	0.42	1.01	2.16	3.31	4.41	5.50	6.56	7.58	8.52	9.33	9.97	10.5	10.8	11.0	11.1	11.2	11.2	11.2
-55	0.12	0.38	1.05	2.37	3.69	4.95	6.20	7.35	8.48	9.60	10.6	11.5	12.2	12.6	12.9	13.1	13.2	13.3	13.4
-50	0.13	0.55	1.52	3.13	4.56	5.99	7.35	8.59	9.84	11.1	12.3	13.3	14.1	14.6	14.9	15.1	15.3	15.5	15.6
-45	0.11	0.48	1.52	3.24	4.80	6.34	7.83	9.11	10.4	11.8	13.4	15.2	17.2	19.3	20.9	21.9	22.7	23.2	23.5
-40	0.12	0.70	2.17	4.01	5.65	7.30	8.82	10.1	11.5	13.2	15.2	17.8	21.2	24.7	27.3	29.0	30.3	31.1	31.4
-35	0.10	0.60	2.08	3.99	5.73	7.46	9.06	10.4	11.7	13.5	16.2	20.8	27.6	36.0	43.7	50.3	56.1	60.5	62.7
-30	0.11	0.86	2.78	4.67	6.50	8.28	9.87	11.2	12.6	14.7	18.8	26.1	37.2	50.6	63.0	74.0	83.9	91.2	94.4
-25	0.08	0.73	2.60	4.56	6.46	8.29	9.92	11.3	12.7	15.0	19.6	29.1	45.1	68.6	98.7	133	170	202	218
-20	0.11	1.16	3.23	5.22	7.17	8.99	10.5	11.9	13.5	16.5	23.4	37.4	61.3	97.8	147	207	270	323	343
-15	0.07	0.96	2.95	4.99	6.99	8.86	10.4	11.8	13.5	16.5	23.4	38.4	67.0	118	201	328	514	748	893
-10	0.12	1.50	3.48	5.57	7.59	9.39	10.9	12.4	14.3	18.4	27.9	48.2	89.1	165	298	513	847	1259	1446
-5	0.07	1.20	3.15	5.27	7.32	9.17	10.7	12.2	14.1	17.8	26.8	46.6	88.7	171	330	640	1313	2354	2970
0	0.13	1.64	3.68	5.81	7.84	9.60	11.1	12.6	15.0	19.8	31.4	57.2	114	226	455	956	2170	3825	4485
5	0.05	1.29	3.24	5.38	7.43	9.27	10.8	12.3	14.3	18.3	28.1	49.8	97.4	192	380	760	1629	3026	3840
10	0.18	1.64	3.66	5.79	7.82	9.60	11.1	12.6	14.9	19.5	31.0	56.0	110	214	414	801	1609	2729	3178
15	0.02	1.29	3.20	5.29	7.32	9.18	10.8	12.2	14.0	17.6	26.4	45.8	85.6	160	292	523	950	1587	1953
20	0.18	1.62	3.56	5.62	7.62	9.42	11.0	12.4	14.2	18.1	27.5	47.4	84.6	148	243	373	530	673	719
25	0.03	1.23	3.03	5.02	6.97	8.84	10.4	11.8	13.4	16.2	22.8	36.9	62.6	104	163	242	334	420	461
30	0.16	1.49	3.28	5.20	7.10	8.93	10.5	11.8	13.4	16.1	22.2	34.5	54.5	80.4	112	146	175	194	200
35	0.04	1.12	2.74	4.56	6.38	8.17	9.78	11.2	12.6	14.6	18.8	26.8	39.8	56.8	76.5	97.3	115	127	132
40	0.15	1.33	2.92	4.64	6.39	8.10	9.66	11.0	12.4	14.4	17.8	23.4	31.4	40.8	49.6	56.5	60.8	62.8	63.2
45	0.06	0.97	2.36	3.95	5.57	7.20	8.75	10.1	11.4	13.1	15.4	18.9	23.7	29.3	34.8	39.1	41.7	42.9	43.2
50	0.13	1.11	2.42	3.89	5.40	6.95	8.41	9.69	11.1	12.6	14.2	16.0	18.1	20.2	21.9	22.9	23.2	23.3	23.3
55	0.08	0.79	1.91	3.20	4.54	5.94	7.29	8.53	9.78	11.1	12.4	13.7	15.1	16.3	17.4	18.0	18.2	18.3	18.3
60	0.12	0.89	1.89	3.03	4.24	5.48	6.69	7.87	9.03	10.1	11.1	11.9	12.5	12.9	13.2	13.2	13.2	13.2	13.3
65	0.09	0.60	1.41	2.35	3.36	4.41	5.46	6.48	7.49	8.46	9.32	10.0	10.6	11.0	11.3	11.4	11.5	11.5	11.5
70	0.12	0.63	1.29	2.07	2.89	3.76	4.63	5.50	6.35	7.16	7.85	8.43	8.87	9.20	9.46	9.63	9.71	9.77	9.80
75	0.10	0.38	0.89	1.46	2.07	2.73	3.40	4.07	4.73	5.35	5.88	6.34	6.72	7.03	7.28	7.45	7.52	7.57	7.60
80	0.12	0.32	0.71	1.09	1.52	1.97	2.44	2.90	3.36	3.76	4.10	4.42	4.70	4.97	5.18	5.31	5.36	5.38	5.40
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

H(β) Range:-90 - 90DEG

H(β) Interval: 1.0DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:CL

Test Date:05 November 2019

V(B) Range:-80 - 80DEG

V(B) Interval: 5.0DEG

Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366

Humidity:65.0%

Test Distance:6.010m [K=1.0000]

Remarks:

### LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.04V I:4.9262A P:580.57W PF:0.9818 Freq:59.98Hz Lamp Flux:82661.8x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:600W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--2

UNIT: ×100cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-80	3.90	3.88	3.83	3.74	3.63	3.49	3.33	3.13	2.91	2.63	2.29	1.96	1.62	1.24	0.87	0.60	0.44	0.23	
-75	5.90	5.90	5.87	5.79	5.66	5.48	5.25	4.96	4.60	4.15	3.63	3.10	2.54	1.95	1.35	0.80	0.53	0.26	
-70	7.91	7.92	7.89	7.80	7.63	7.40	7.06	6.65	6.11	5.47	4.76	4.02	3.23	2.43	1.57	0.86	0.52	0.18	
-65	9.58	9.58	9.57	9.52	9.41	9.21	8.88	8.42	7.81	7.03	6.16	5.24	4.28	3.28	2.25	1.18	0.64	0.24	
-60	11.2	11.2	11.2	11.2	11.1	10.9	10.5	9.97	9.22	8.24	7.19	6.08	4.93	3.73	2.47	1.21	0.60	0.15	
-55	13.4	13.3	13.3	13.2	13.1	13.0	12.5	11.8	10.8	9.67	8.48	7.27	5.98	4.63	3.27	1.73	0.78	0.22	
-50	15.5	15.4	15.3	15.2	15.1	14.8	14.2	13.2	12.0	10.6	9.30	7.97	6.50	4.97	3.48	1.71	0.72	0.12	
-45	23.4	23.1	22.6	22.0	21.0	19.6	17.7	15.6	13.6	11.8	10.4	9.01	7.46	5.81	4.17	2.42	0.89	0.20	
-40	31.3	30.7	29.7	28.4	26.4	23.7	20.4	17.1	14.4	12.4	10.9	9.47	7.78	5.99	4.23	2.35	0.75	0.10	
-35	62.2	59.0	54.1	48.3	42.0	34.8	27.2	20.7	16.1	13.4	11.8	10.3	8.62	6.78	4.91	3.02	1.05	0.18	
-30	92.2	85.6	76.3	65.8	54.8	42.8	31.2	22.2	16.5	13.6	12.0	10.5	8.74	6.82	4.84	2.88	0.83	0.09	
-25	211	185	150	116	85.5	60.5	41.2	27.1	18.6	14.6	12.6	11.2	9.44	7.50	5.46	3.41	1.31	0.15	
-20	321	271	210	153	105	69.8	44.6	27.7	18.6	14.5	12.7	11.2	9.40	7.38	5.25	3.12	1.03	0.06	
-15	798	571	379	246	154	94.3	56.4	33.5	21.0	15.5	13.2	11.6	9.94	7.98	5.84	3.65	1.56	0.13	
-10	1191	782	487	296	174	101	57.0	32.9	20.5	15.3	13.1	11.5	9.76	7.74	5.55	3.29	1.28	0.05	
-5	2515	1473	740	402	223	124	68.2	38.2	22.8	16.2	13.5	11.8	10.2	8.24	6.04	3.76	1.64	0.13	
0	3459	1783	815	419	221	119	64.2	35.5	21.4	15.7	13.2	11.6	9.87	7.87	5.63	3.32	1.26	0.05	
5	3214	1811	862	452	243	132	71.3	39.2	23.2	16.4	13.6	11.9	10.2	8.28	6.07	3.76	1.62	0.14	
10	2448	1340	688	378	208	115	62.0	34.6	21.1	15.6	13.2	11.5	9.83	7.81	5.58	3.28	1.24	0.00	
15	1663	1028	578	340	198	114	63.8	36.1	22.0	15.9	13.4	11.8	10.1	8.08	5.89	3.63	1.55	0.14	
20	635	490	349	233	147	88.4	51.6	30.2	19.4	14.9	12.9	11.3	9.55	7.49	5.30	3.08	1.15	0.00	
25	427	349	264	188	128	82.2	50.5	30.4	19.7	15.0	13.0	11.4	9.66	7.65	5.53	3.38	1.42	0.12	
30	192	174	147	117	87.7	61.2	39.5	25.1	17.5	14.1	12.4	10.8	9.01	6.97	4.90	2.83	1.05	0.00	
35	129	119	105	88.7	71.1	53.0	36.5	24.3	17.4	14.0	12.2	10.7	8.92	6.96	4.97	3.00	1.26	0.11	
40	62.3	60.2	57.4	53.5	47.2	37.8	27.7	20.0	15.5	13.0	11.4	9.88	8.06	6.15	4.26	2.42	0.90	0.00	
45	42.9	42.0	40.7	39.0	36.1	30.9	24.4	18.8	15.0	12.6	11.0	9.51	7.81	6.00	4.23	2.52	1.06	0.10	
50	23.2	23.2	23.3	23.5	23.3	21.6	18.7	15.7	13.3	11.5	9.98	8.50	6.83	5.14	3.51	1.98	0.75	0.00	
55	18.3	18.3	18.4	18.5	18.6	17.9	16.2	14.1	12.3	10.7	9.22	7.84	6.34	4.81	3.35	1.97	0.85	0.10	
60	13.3	13.3	13.4	13.6	13.8	13.6	12.8	11.7	10.5	9.22	7.91	6.60	5.23	3.89	2.62	1.46	0.56	0.00	
65	11.5	11.5	11.6	11.6	11.6	11.5	10.9	10.1	9.07	7.99	6.87	5.75	4.59	3.44	2.37	1.40	0.62	0.09	
70	9.80	9.78	9.73	9.62	9.44	9.16	8.68	8.03	7.22	6.32	5.39	4.45	3.48	2.55	1.71	0.98	0.39	0.02	
75	7.60	7.58	7.53	7.43	7.24	6.99	6.62	6.16	5.58	4.90	4.19	3.47	2.74	2.04	1.41	0.84	0.39	0.08	
80	5.39	5.37	5.29	5.18	4.96	4.69	4.40	4.07	3.68	3.21	2.69	2.20	1.72	1.26	0.88	0.50	0.23	0.04	
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

H(β) Range:-90 - 90DEG

H(β) Interval: 1.0DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:CL

Test Date:05 November 2019

V(B) Range:-80 - 80DEG

V(B) Interval: 5.0DEG

Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.366

Humidity:65.0%

Test Distance:6.010m [K=1.0000]

Remarks: