

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	5732.2 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	39.7V x 40.8H
	At 50% of Imax	17.4V x 19.1H
	At 90% of Imax	5.2V x 7.5H

Beam Flux	Total	998.4 lumens per klm.
	To 10% of Imax	716.8 lumens per klm.
	To 50% of Imax	291.7 lumens per klm.
	To 90% of Imax	28.2 lumens per klm.

Upward LOR	0.0 %
Downward LOR	99.8 %


Luminaire Efficiency (Light Output Ratio)	100.0 %
---	---------

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:11 November 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:120.08V I:6.5686A P:774.92W PF:0.9825 Freq:59.98Hz Lamp Flux:104590x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:800W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



DATA OF LAMP		Eff:134.97lm/W	
NJZMODEL800-V01-RZ-15-PC-BL		Imax(cd)	599533
NOMINAL POWER(W)	800	AVAILABILITY(%)	73.4
RATED VOLTAGE(V)	120	Avai. FLUX(lm)	76775
NOMINAL FLUX(lm)	104590	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	104590
TEST VOLTAGE(V)	120	θ @50% (H,V)	19,17DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
80	0.15	1.44	4.26	8.59	14.0	19.3	24.1	27.4	29.1	29.2	27.7	24.7	20.1	14.6	9.02	4.49	1.52	0.18	260	0.00
70	0.27	2.38	7.12	14.3	23.0	31.9	39.2	43.6	45.6	45.8	44.3	40.5	33.5	24.1	15.0	7.44	2.48	0.28	421	0.00
60	0.41	3.47	10.2	20.1	32.2	45.5	57.8	65.0	67.6	67.8	66.4	62.0	49.7	34.2	21.0	10.6	3.59	0.42	618	0.00
50	0.53	4.47	13.0	24.8	40.0	62.6	95.0	121	131	132	127	110	73.4	43.2	25.8	13.4	4.62	0.54	1023	0.00
40	0.64	5.32	15.1	28.1	46.5	90.3	182	285	353	361	311	217	110	51.2	29.2	15.6	5.46	0.64	2109	0.00
30	0.72	5.96	16.5	30.2	53.1	133	348	717	1086	1122	793	411	160	59.6	31.6	17.1	6.13	0.73	4990	190
	0.79	6.41	17.4	31.6	60.4	183	617	1753	3900	4164	1957	698	214	68.2	33.1	18.0	6.56	0.79	13729	10051
	0.82	6.61	17.7	32.3	65.3	220	885	3422	10467	10796	3656	952	252	74.0	33.9	18.3	6.78	0.82	30907	28268
	0.82	6.60	17.6	32.3	65.3	220	900	3904	12334	11734	3571	898	241	72.7	33.7	18.3	6.72	0.81	34056	31377
	0.77	6.33	17.1	31.2	59.5	177	597	1653	3061	2705	1408	561	188	65.2	32.7	17.8	6.45	0.76	10587	6888
	0.69	5.87	16.2	29.5	51.7	124	295	495	522	494	422	262	125	54.9	30.8	16.7	5.93	0.66	2952	0.00
-30	0.57	5.17	14.6	26.9	44.1	79.9	132	153	152	148	138	122	79.4	46.0	28.0	14.9	5.19	0.53	1190	0.00
-40	0.45	4.31	12.4	23.4	37.3	54.2	68.3	73.3	73.5	72.2	70.6	65.0	53.2	38.0	24.0	12.5	4.22	0.39	687	0.00
-50	0.32	3.26	9.63	18.6	29.3	39.2	45.1	48.0	49.6	49.6	48.0	44.9	39.2	29.6	18.9	9.61	3.15	0.28	486	0.00
-60	0.22	2.17	6.49	12.8	20.3	27.3	32.6	36.2	37.8	37.8	36.3	32.7	27.2	20.2	12.8	6.38	2.02	0.17	352	0.00
-70	0.13	1.15	3.38	6.73	10.7	14.6	17.9	20.0	21.1	21.1	20.0	17.7	14.4	10.5	6.59	3.22	1.02	0.10	190	0.00
-80	0.05	0.29	0.68	1.23	1.90	2.58	3.19	3.62	4.03	3.93	3.49	2.97	2.30	1.59	0.92	0.46	0.15	0.01	33.4	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL (DEG)	20	30	40	50	60	70	80	90			
Φ t	8.35	71.2	199	373	655	1524	4338	12821	32334	31984	12700	4521	1681	708	387	205	72.0	8.10	104590	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	316	8820	29504	29223	8705	206	0.00	0.00	0.00	0.00	0.00	0.00	---	76775

one-half-peak spread: U:7.7,D:9.9 , L:9.8,R:9.5


NEMA Beam Type: Type 3

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:11 November 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:120.08V I:6.5686A P:774.92W PF:0.9825 Freq:59.98Hz Lamp Flux:104590x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:800W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A




H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:11 November 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:120.08V I:6.5686A P:774.92W PF:0.9825 Freq:59.98Hz Lamp Flux:104590x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:800W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:11 November 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(β) Range:-90 - 90DEG
 H(β) Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:11 November 2019

V(B) Range:-80 - 80DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

AAI Figure

Test:U:120.08V I:6.5686A P:774.92W PF:0.9825 Freq:59.98Hz Lamp Flux:104590x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:800W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Flux out:31144 lm



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:11 November 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.08V I:6.5686A P:774.92W PF:0.9825 Freq:59.98Hz Lamp Flux:104590x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:800W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--1

UNIT: ×100cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.13	0.25	0.57	0.91	1.20	1.51	1.83	2.16	2.49	2.79	3.05	3.29	3.51	3.68	3.79	3.89	3.99	4.09	4.11
-75	0.09	0.23	0.66	1.26	1.85	2.43	3.06	3.67	4.27	4.83	5.32	5.74	6.10	6.40	6.61	6.75	6.85	6.93	6.97
-70	0.13	0.48	1.22	2.08	2.96	3.85	4.78	5.67	6.51	7.27	7.94	8.50	8.95	9.31	9.55	9.69	9.77	9.82	9.82
-65	0.07	0.36	1.19	2.34	3.51	4.66	5.85	7.00	8.10	9.14	10.0	10.8	11.4	11.8	12.1	12.3	12.4	12.5	12.5
-60	0.14	0.74	2.05	3.54	4.97	6.43	7.86	9.24	10.5	11.8	12.8	13.6	14.2	14.6	14.9	15.1	15.2	15.2	15.3
-55	0.06	0.49	1.82	3.56	5.26	6.96	8.63	10.2	11.7	13.2	14.6	15.7	16.7	17.3	17.6	17.8	17.9	18.1	18.2
-50	0.15	1.05	2.95	4.98	6.90	8.86	10.7	12.4	14.1	15.8	17.3	18.7	19.7	20.2	20.4	20.6	20.8	21.0	21.1
-45	0.04	0.64	2.52	4.76	6.88	9.02	11.1	12.9	14.7	16.6	18.9	21.4	24.2	26.6	28.2	29.3	30.2	30.8	31.1
-40	0.16	1.49	3.88	6.26	8.57	10.9	13.0	14.8	16.8	19.2	22.3	26.3	30.8	34.5	37.0	38.8	40.1	40.9	41.0
-35	0.02	0.83	3.20	5.77	8.23	10.7	13.0	14.9	16.8	19.3	23.3	29.7	38.8	49.2	58.3	65.7	72.1	77.1	79.6
-30	0.17	1.89	4.61	7.25	9.85	12.4	14.6	16.5	18.7	22.2	28.8	39.8	55.2	71.7	85.8	98.0	109	116	118
-25	0.01	1.07	3.77	6.56	9.28	11.9	14.3	16.3	18.4	21.9	28.8	42.5	65.2	97.3	137	183	232	274	295
-20	0.18	2.33	5.19	8.06	10.8	13.4	15.7	17.7	20.4	25.9	37.7	61.1	98.7	153	223	307	392	455	471
-15	0.00	1.37	4.16	7.12	10.0	12.7	15.0	17.2	19.7	24.4	34.8	57.5	99.9	174	293	479	753	1108	1343
-10	0.19	2.57	5.49	8.53	11.4	14.0	16.2	18.5	22.0	29.2	46.3	81.4	151	277	492	842	1388	2012	2212
-5	0.00	1.57	4.35	7.43	10.4	13.1	15.4	17.6	20.6	26.3	39.5	69.1	131	248	471	905	1820	3203	4094
0	0.20	2.66	5.67	8.75	11.7	14.2	16.4	18.8	22.8	31.2	51.2	95.2	185	364	726	1548	3293	5369	5932
5	0.00	1.60	4.38	7.46	10.4	13.2	15.5	17.7	20.8	26.5	40.2	71.1	136	260	498	963	1952	3465	4445
10	0.29	2.59	5.54	8.60	11.5	14.1	16.3	18.6	22.3	30.0	48.4	87.5	166	309	566	1004	1750	2631	2910
15	0.00	1.56	4.23	7.21	10.1	12.9	15.2	17.4	20.1	25.1	36.7	62.3	112	199	346	582	951	1454	1788
20	0.28	2.48	5.29	8.21	11.1	13.7	15.9	18.1	21.1	27.1	41.0	68.7	117	190	291	413	539	634	659
25	0.00	1.45	3.91	6.71	9.51	12.2	14.6	16.7	19.0	22.9	30.9	47.9	77.4	122	182	254	331	396	428
30	0.25	2.22	4.76	7.46	10.2	12.7	15.0	17.0	19.5	23.6	31.8	47.1	70.1	98.1	128	157	180	194	198
35	0.00	1.28	3.45	5.97	8.52	11.1	13.4	15.5	17.6	20.5	25.4	34.2	48.5	66.4	85.3	103	118	128	132
40	0.21	1.94	4.13	6.51	8.95	11.4	13.6	15.6	17.8	20.7	24.8	31.5	40.4	49.7	57.2	62.1	64.8	66.0	66.5
45	0.00	1.07	2.89	5.02	7.23	9.50	11.7	13.7	15.6	17.9	20.8	24.6	30.0	35.7	40.7	44.1	45.9	46.8	47.2
50	0.17	1.56	3.32	5.28	7.33	9.43	11.4	13.3	15.2	17.3	19.4	21.8	24.2	26.1	27.3	27.8	27.9	27.9	28.0
55	0.00	0.81	2.24	3.90	5.66	7.51	9.33	11.1	12.8	14.6	16.3	18.0	19.8	21.2	22.2	22.7	22.8	22.8	22.9
60	0.12	1.15	2.45	3.91	5.47	7.07	8.68	10.3	11.8	13.2	14.6	15.7	16.7	17.3	17.6	17.7	17.8	17.8	17.8
65	0.05	0.53	1.56	2.71	3.94	5.25	6.60	7.93	9.24	10.5	11.6	12.6	13.5	14.1	14.5	14.8	14.9	14.9	15.0
70	0.10	0.68	1.56	2.47	3.44	4.51	5.59	6.65	7.70	8.66	9.54	10.3	10.9	11.4	11.7	11.9	12.1	12.2	12.2
75	0.08	0.29	0.87	1.54	2.24	2.97	3.75	4.51	5.29	6.02	6.68	7.24	7.75	8.15	8.48	8.69	8.85	8.95	8.99
80	0.09	0.30	0.72	1.17	1.60	2.05	2.52	3.00	3.49	3.92	4.30	4.65	4.97	5.24	5.44	5.61	5.74	5.80	5.81
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

H(β) Range:-90 - 90DEG

H(β) Interval: 1.0DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:CL

Test Date:11 November 2019

V(B) Range:-80 - 80DEG

V(B) Interval: 5.0DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366

Humidity:65.0%

Test Distance:6.010m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.08V I:6.5686A P:774.92W PF:0.9825 Freq:59.98Hz Lamp Flux:104590x1 lm		
NAME: LED High Bay Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:800W	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--2

UNIT: ×100cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-80	4.05	3.95	3.84	3.74	3.59	3.40	3.19	2.95	2.67	2.35	2.01	1.68	1.36	1.05	0.72	0.36	0.16	0.12	
-75	6.94	6.89	6.79	6.66	6.47	6.20	5.89	5.49	5.05	4.52	3.94	3.31	2.67	2.07	1.44	0.82	0.31	0.12	
-70	9.79	9.75	9.64	9.44	9.15	8.77	8.28	7.69	7.03	6.25	5.37	4.43	3.49	2.58	1.66	0.82	0.25	0.10	
-65	12.5	12.5	12.4	12.2	12.0	11.6	11.1	10.4	9.60	8.64	7.54	6.36	5.18	3.97	2.74	1.53	0.55	0.12	
-60	15.2	15.2	15.1	14.8	14.5	14.1	13.4	12.5	11.4	10.2	8.77	7.35	5.89	4.38	2.84	1.35	0.37	0.09	
-55	18.1	18.0	17.9	17.7	17.4	17.0	16.3	15.3	14.1	12.6	11.0	9.39	7.73	5.97	4.21	2.39	0.83	0.11	
-50	21.0	20.8	20.6	20.3	20.0	19.5	18.5	17.2	15.6	13.8	12.0	10.1	8.17	6.16	4.12	2.04	0.51	0.07	
-45	30.9	30.3	29.5	28.5	27.2	25.4	23.1	20.6	18.2	16.0	14.0	12.1	10.0	7.81	5.61	3.30	1.15	0.11	
-40	40.4	39.2	37.6	35.6	33.0	29.5	25.6	22.0	19.1	16.6	14.5	12.4	10.1	7.69	5.31	2.72	0.68	0.05	
-35	78.3	73.7	67.4	60.6	52.9	43.9	35.0	27.5	22.2	18.7	16.3	14.2	11.9	9.37	6.82	4.21	1.56	0.12	
-30	113	103	91.9	79.8	65.9	51.0	38.0	28.3	22.1	18.7	16.4	14.2	11.7	9.01	6.30	3.49	0.85	0.03	
-25	285	249	201	154	112	79.1	54.7	37.2	26.4	20.8	17.9	15.7	13.3	10.6	7.78	4.94	2.02	0.13	
-20	432	358	272	193	130	85.8	55.7	36.0	25.2	20.2	17.6	15.4	12.8	9.94	7.00	4.02	1.10	0.00	
-15	1228	884	569	359	219	132	79.4	48.3	30.8	22.6	18.9	16.6	14.2	11.4	8.46	5.40	2.41	0.13	
-10	1770	1130	677	398	228	129	74.2	43.9	28.2	21.4	18.3	16.0	13.5	10.6	7.48	4.33	1.45	0.00	
-5	3633	2283	1160	606	329	180	98.8	56.4	34.1	23.9	19.5	17.0	14.6	11.9	8.82	5.65	2.59	0.14	
0	4492	2392	1095	550	289	154	82.9	47.4	29.5	22.0	18.5	16.1	13.6	10.8	7.64	4.41	1.55	0.00	
5	3934	2454	1240	644	348	188	102	57.5	34.5	24.0	19.6	17.0	14.6	11.9	8.87	5.67	2.60	0.20	
10	2272	1396	794	455	256	142	78.4	45.3	28.7	21.7	18.4	16.0	13.6	10.7	7.57	4.38	1.57	0.00	
15	1620	1132	708	437	263	153	87.9	51.3	31.8	23.0	19.1	16.7	14.3	11.6	8.59	5.47	2.50	0.24	
20	604	497	374	262	169	104	63.2	38.4	26.0	20.5	17.8	15.6	13.0	10.1	7.14	4.09	1.43	0.00	
25	415	364	294	222	157	104	66.1	41.5	27.8	21.4	18.3	16.0	13.6	10.9	8.00	5.06	2.30	0.22	
30	192	178	155	129	99.4	70.3	46.8	31.4	23.2	19.2	16.9	14.6	12.1	9.33	6.53	3.73	1.29	0.00	
35	131	125	115	101	84.0	64.5	46.0	32.3	23.9	19.5	16.9	14.8	12.4	9.80	7.13	4.47	2.03	0.19	
40	66.3	65.5	63.8	60.4	53.4	43.1	32.8	25.3	20.4	17.5	15.3	13.1	10.7	8.11	5.61	3.17	1.10	0.00	
45	47.3	47.0	46.5	45.4	42.6	37.2	30.5	24.5	20.2	17.2	15.0	12.9	10.7	8.32	6.00	3.73	1.69	0.15	
50	28.1	28.2	28.5	28.7	28.1	26.0	22.9	19.9	17.3	15.0	13.0	11.0	8.84	6.66	4.56	2.56	0.88	0.02	
55	22.9	23.0	23.2	23.3	23.2	22.3	20.4	18.2	16.1	14.1	12.2	10.4	8.49	6.54	4.66	2.88	1.29	0.12	
60	17.8	17.9	18.0	18.0	17.8	17.2	16.1	14.7	13.2	11.6	9.95	8.26	6.57	4.90	3.32	1.86	0.60	0.05	
65	15.0	15.0	15.0	15.0	14.8	14.4	13.6	12.6	11.4	10.1	8.72	7.34	5.93	4.53	3.21	1.96	0.84	0.11	
70	12.2	12.1	12.0	11.8	11.5	11.0	10.4	9.53	8.55	7.51	6.40	5.30	4.16	3.08	2.09	1.14	0.39	0.06	
75	9.00	8.96	8.86	8.72	8.48	8.14	7.69	7.14	6.48	5.73	4.94	4.16	3.33	2.54	1.82	1.11	0.47	0.11	
80	5.79	5.72	5.59	5.43	5.22	4.95	4.62	4.25	3.83	3.34	2.84	2.37	1.86	1.41	0.98	0.53	0.21	0.07	
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

H(β) Range:-90 - 90DEG

H(β) Interval: 1.0DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:CL

Test Date:11 November 2019

V(B) Range:-80 - 80DEG

V(B) Interval: 5.0DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366

Humidity:65.0%

Test Distance:6.010m [K=1.0000]

Remarks: