


Explosion-proof LED Luminaire

General Safety Information

- To reduce the risk of death, personal injury or property damage from fire, electric shock, falling parts, cuts/abrasions and other hazards, please read all warnings and instructions included with and on the fixture box and all fixture labels
- Before installing, servicing, or performing routine maintenance upon this equipment, please follow these general precautions
- Commercial installation, service and maintenance of luminaires should be performed by a qualified licensed electrician
- **DO NOT INSTALL DAMAGED PRODUCT!**
- Make sure that the supply voltage is the same as the luminaire voltage
- Do not install where the marked operating temperatures exceed the ignition temperatures of the hazardous atmosphere
- Do not operate in ambient temperatures above those indicated on the luminaire nameplate
- All gasket seals must be clean and undamaged.



SPECIAL CONDITIONS OF USE

1. To minimize the electrostatic discharge, wipe the enclosure surface with a damp cloth only.
2. The cable entry holes must be connected by means of suitable cable entry devices which are certified separately with ATEX certificate and the IP degree of cable entries shall be IP66 as a minimum. No tension or pulling is allowed on the entry cable, it can impair the explosion safety of the equipment.
The unused entry holes must be blocked by means of suitable blanking elements which are separately certified separately with ATEX certificate and the IP degree of blanking elements shall be IP66 as a minimum.
4. The installation must be installed according to the requirements of EN 60079-14: latest version (or its National equivalent standards).
5. The Ni-cd secondary battery KRH26/51(C)2500TX8, 9.6V in the emergency LED linear explosion-proof light must be only replaced by the manufacturer or NJZ authorized distribution partner

Explosion-proof LED Luminaire

Nameplate (ATEX & IECEx)



LED Linear Explosion proof light

II 2 G Ex db eb mb IIC T6 Gb Ex db eb mb IIC T6 Gb Ta. (Standard) -40°C~+55°C
 II 2 D Ex tb IIIC T80°C Db Ex tb IIIC T80°C Db Ta. (Emergency) -20°C~+50°C
 CERT: TPS 20 ATEX 095986 0026 X IECEx TPS 19.0024X

Model: NJZ-FEL-G-60 Ordering#: NJZ-FEL-G-60-V01-RZ-F-IAC-002
 Cable Entry: 4 x M25 x 1.5 Serial No.: 2105-ZZZ

60 W, 120-277V AC, 50/60Hz, 5000 K, IP66, IK10 21: Year 2021 05: Week 05 ZZZ: Serial number

WARNING – DO NOT OPEN WHEN ENERGIZED
 WARNING – DO NOT OPEN WHEN AN EXPLOSIVE ATMOSPHERE IS PRESENT
 WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD-SEE INSTRUCTIONS

CE0123

No.58 Hengguang Rd., Nanjing, China,210038

Model: NJZ-FEL-G-60(LED linear explosion proof light)

Ordering#: Means the model catalog #

Cable Entry: For example: 4*M25*1.5, means the type of thread

Serial No: XXYYZZZ XX:Year YY:Week ZZZ:Serial number

60W means the rated power 60W

5000K means the color temperature

IK means impact protection degree

IP means dustproof and waterproof degree

Tamb: -20 C to +50 C (Operating temperature range of the Emergency model)

0123 means the Number of notify body that released the QAN

WARNING:

WARNING – DO NOT OPEN WHEN AN EXPLOSIVE IS PRESENT.

WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD – SEE INSTRUCTIONS.

WARNING – DO NOT OPEN WHEN ENERGIZED.

WARNING – DO NOT TRANSPORT THROUGH A HAZARDOUS AREA

CAUTION:


You can prevent static electricity by wiping with a wet cloth;

Wear gloves and safety glasses at all times when removing luminaire from carton, installing, servicing or performing maintenance;


Avoid direct eye exposure to the light source while it is on;

Properly handle small parts and destroy packing material,as these may be hazardous to children.

ATEX:



IECEx:



Explosion-proof LED Luminaire

Warranty

We warrant that each of our LED lighting luminaire (the “Product(s)”) that are purchased while this Warranty is in effect will be free from defects in materials and workmanship for the period of time specified in the table below (the “Warranty Period”). The Warranty Period runs from the date of original purchase from its authorized distributor/dealer.

We will repair, or at our option, replace the defective product (exterior finish, housing and heat sinks, lens, LED engine, power supply) during the standard warranty period. This warranty applies only to the repair or replacement of the product and only when the product is properly handled, installed and maintained according to our instructions.

This warranty excludes defects resulting from improper installation, acts of God, fire, vandalism or civil disturbances, power surges or improper power supply, and corrosive environment installations.

This warranty does not cover equipment, systems or components from other manufacturers that the Purchaser uses in conjunction with the Product. Any repair, alteration or modification of the Product, including replacement of Product components with components of other manufacturers will void the warranty in its entirety.

Product	Which Model Nos. are Covered by this Warranty	Warranty Period
Explosion-protected Luminaire	NJZ-FEL-G Series	Five (5) Years
Battery	NJZ-FEL-G Series	One (1) Year

Limitation of Liability

THE FOREGOING WARRANTY IS EXCLUSIVE, AND IS THE SOLE REMEDY FOR ANY AND ALL CLAIMS, WHETHER IN CONTRACT, IN TORT OR OTHERWISE ARISING FROM THE FAILURE OF PRODUCT AND IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING ALL WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, WHICH WARRANTIES ARE HEREBY EXPRESSLY DISCLAIMED TO THE EXTENT PERMITTED BY LAW AND, IN ANY EVENT, SHALL BE LIMITED TO THE WARRANTY PERIOD SPECIFIED ABOVE. THE LIABILITY OF SHALL BE LIMITED TO THE TERMS OF THE EXPRESS WARRANTY SET FORTH HERE IN. IN NO EVENT WILL BE LIABLE FOR ANY SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES INCLUDING, WITHOUT LIMITATION, DAMAGES RESULTING FROM LOSS OF USE, PROFITS, BUSINESS OR GOODWILL, LABOR COSTS, REMOVAL OR INSTALLATION COSTS, DECREASE IN THE LIGHT OUTPUT OF THE LAMP, AND/OR DETERIORATION IN THE LAMP'S PERFORMANCE, WHETHER OR NOT HAS BEEN ADVISED OF THE POSSIBILITY THEREOF. UNDER NO CIRCUMSTANCES SHALL 'S ENTIRE LIABILITY FOR A DEFECTIVE PRODUCT EXCEED THE PURCHASE PRICE OF THAT PRODUCT. WARRANTY SERVICES PROVIDED UNDER THESE TERMS AND CONDITIONS DO NOT ENSURE THE UNINTERRUPTED OPERATION OF PRODUCTS; SHALL NOT BE LIABLE FOR DAMAGES CAUSED BY ANY DELAYS INVOLVING WARRANTY SERVICE.

This Limited Warranty gives you specific legal rights and you may also have other rights that may vary from state to state. Because some states or jurisdictions do not allow the exclusion or limitation of liability for consequential or incidental damages, this limitation may not apply to you.

Explosion-proof LED Luminaire

Inspection

Within the scope of maintenance or inspection routine the following should be included:

- Protective hoses covering the connection cables
- Cable entries must be free of corrosion.
- Perform visual mechanical and electrical inspections on a regular basis. We recommend routine checks to be made on a yearly basis.
- The PC cover should be cleaned periodically as needed to ensure continued photometric performance.
- Inspect the luminaire to ensure that it is free of any obstructions or contamination (i.e. excessive dust build up). Clean with a non-abrasive, damp cloth if needed.

Internal and external grounding

Internal earthing are provided in the terminal compartment and end shield. The internal earthing bolt: M4X6, torque is 3Nm, the section area of internal earthing wire is 0.84 mm².

The external bonding is provided on the external surface of end shield. The bolt is M6X10 hexagon socket cap screws. The external earthing wire is 4 mm². The torque of external bonding is 4Nm. External bondings are secured against loosen.

Open the light

Use hexagonal wrench to open the screw of metallic press board of light-transmission and the end cover of enclosure then the LED driver can be installed or replaced by the end user. How to replace the LED driver shall be contact to NJZ authorized distribution partner or NJZ. The driver must not be replaced by other brands.

Explosion-proof LED Luminaire

Installation & Operation

Models:

NJZ-FEL-G-3-4

3= Power (20=20W, 30=30W, 40=40W, 50=50W, 60=60W, 80=80W, 100=100W)

4= Emergency mode

EM6=6W 180mins

EM12=12W 90mins (Emergency Standard)

Operating characteristic:

Rated voltage:	Power	Model	T-Class	Ambient Temp, (Emergency mode)
120-277 Vac	20W	NJZ-FEL-G-20	T6	-20°C~+50°C
	30W	NJZ-FEL-G-30		
	40W	NJZ-FEL-G-40		
	50W	NJZ-FEL-G-50		
	60W	NJZ-FEL-G-60	T5	
	80W	NJZ-FEL-G-80		
	100W	NJZ-FEL-G-100		

General Wiring Diagram


CAUTION:

Explosion-proof LED Luminaire

Turn off electrical power at fuse or circuit breaker box before wiring fixture to the power supply

Necessary operation

Expand functionality



NOTE: Battery BAT1 and BAT2 should be Insert connector before use;

NOTE: The default emergency power is 12W ,if you want to switch to 6W ,PS1 and PS2 need to be connected.

Explosion-proof LED Luminaire

Installation & Operation

Electrical Connection

1. Loosen the four pcs of M4 hexagon bolts of terminal cover at torque value 3 N-m;
2. The thread of entry hole of Tank is M20、M25、1/2” NPT、3/4”NPT. Connect the Tank to suitable conduit;
3. The user shall be equipped the cable entry device with an explosion-proof lead-in device and the plug is M20、M25、1/2” NPT、3/4”NPT; Inset the wire from outside through the conduit and the entry hole of Tank, and then connect to terminal block;
4. Introduce the wires of branch circuit as following:
 Brown-wire connects to Line
 Brown -wire connects to Wall Switch
 Blue-wire connects to Neutral
 Green-wire connects to Ground
5. Connect the Battery BAT1 and BAT2 ;
6. Re-attach the terminal cover and tighten it by four pcs of M4 hexagon bolts of terminal cover at torque value 3 N-m;
7. Check the tightness of conduit and terminal cover.

NOTE: Parts necessary to achieve a specific type of protection or used to prevent access to uninsulated live parts shall be capable of being released or removed only with the aid of a tool.


NOTE: Further information on the installation of conduit or associated fittings into threaded or plain holes can be found in EN 60079-14.

The Battery Replacement

1. Loosen the five pcs of M6 hexagon bolts of end cap at torque value 4 N-m;
2. Pull out the end cap;
3. Disconnect the wires connecting the wago 211 terminal with the luminaire ;
4. Loosen the nylon cable ties on the battery pack;
5. Replace with a new battery pack and tighten nylon cable ties;
6. Connect the wires connecting the wago 211 terminal with the luminaire ;
7. Close end cap at torque value 4 N-m
 (The battery fixing plate shall be inserted into the tank of the lamp housing).

NOTE: Battery replacement needs to be done in a non-hazardous location!

NOTE: Do not reverse charge batteries!



Explosion-proof LED Luminaire

Certificates



Repair and maintenance work shall be conducted by the end user only after the LED linear light isn't energized. Repair and maintenance shall be conformed to EN&IEC 60079-19.

In addition, the relevant national regulation which apply to the maintenance/servicing of electrical apparatus in explosive atmospheres shall be observed.

Any unforeseen repairs or overhaul may only be carried out with NJZ spare parts. LED driver and LED lens chamber must not be repaired by the end user.


NOTE: Should the luminaire enclosure be damaged, only a full luminaire replacement will be permitted. In case of doubt, the equipment should be returned to NJZ for inspection/repair.

WARNING:
 Modifications to the device or changes of its design are not permitted.

This equipment must be operated according to the intended purpose in a perfect and undamaged condition.

Explosion-proof LED Luminaire

Wall Mounting Outreach :



Servicing

To avoid personal injury, disconnect power to the light and allow the unit to cool down before performing maintenance.
 Perform visual, electrical, and mechanical inspections on a regular basis. The environment and frequency of use should determine this. However, it is recommended that checks should be made at least once a year.
 The external Lens should be cleaned periodically to ensure continued luminaire performance. Clean the Lens with a clean, damp, non-abrasive, lint-free cloth. If this is not sufficient, use a mild soap or a liquid cleaner. Do not use an abrasive, strong alkaline or acid cleaner as damage may occur.
 Inspect the cooling fins of the luminaire to ensure that they are free of any contamination (i.e. excessive dust build-up). Clean with a non-abrasive cloth if needed.
 Mechanically check to make sure all parts are properly assembled.
 Electrically check to make sure that all connections are clean and tight

Explosion-proof LED Luminaire


The battery parameter

Brand: DISON **Pitch number:** 8
Type: KRH26/51(C)2500TX8 9.6V **Series-parallel:** In series
Capacity: 2500mAH **Voltage:** 9.6V

NOTE: We recommend cells or batteries are charged and discharged at least once every 6 months. Charge at 0.1 ItA for 16hrs, rest 10min, then discharge with 0.2 ItA to 1.0V/cell. then charge at 0.2ItA to 120min.
NOTE: The battery in not before use, please don't and circuit connection, prevent due to the circuit board to consumption overdischarge and damage to the battery.


WARNING – DO NOT TRANSPORT THROUGH A HAZARDOUS AREA

Product Size:



Installation :


Low Ceiling Mount :




Unit: mm

Explosion-proof LED Luminaire

High Ceiling Mount :




Eyebolt Mount :




Explosion-proof LED Luminaire


Wall Mount :



Safety rope Mount :



Pole Mount Clamp :



Code	Description	A	B	C	D
PC-48	Dia40-51mm range	92	72	18	42
PC-60	Dia54-62mm range	105	84	28	46